



## MEDIUM VOLTAGE ARMoured CABLES: IEC 60502-2

### Application


These Medium Voltage Single Core & Three Core Cables are Designed for Electricity Power Distribution, Suitable for Installation in Power Supply Stations, Commercial, Industrial and Urban Residential Networks, Indoors and in Cable Ducts, Outdoors, Undergrounds and as well as for Installation on Cable Trays for industries, Switchboards and the power Stations with Nominal Voltage  $U_0/U$  Ranging from 3.6/6 kV to 18/30 kV.

### Construction

- Conductor** : Annealed Plain Copper or Aluminium Compacted Round Stranded Conductors to carry Current and withstand Pulling Stresses During Cable Laying. Conductors Complying with IEC 60228
- Inner Semi-Conducting Screen** : Extruded Layer of Semi-Conducting Screen over Conductor to Smooth the Electric Field at the Conductor and Firmly Bonded to the Insulation to exclude all air voids and Prevent Concentration of electric field of the interface between the Insulation and the Inner Semi-Conductor. Semi-Conducting Compound Complying with IEC 60502-2
- Insulation** : The Insulation of XLPE ( Cross-Linked Polyethylene ) Rated Voltage, Lightning Overvoltage, Switching Overvoltage and Withstand the Various Voltage Field Stress During the Cable Service Life as per IEC 60502-2
- Core Semi-Conducting Screen** : Extruded Layer of Semi-Conducting Screen over the Insulation. The Screen is Tightly Fitted to the Insulation to Exclude all air Voids, Prevent Concentration of electric field of the interface between the Insulation and the Semi-Conductor. Semi-Conducting Compound Complying with IEC 60502-2
- Metallic Screen** : The Metallic Screen Shall Consist of Copper Tape. The Metallic Layer may be applied over the Individual Cores. Metallic Screen Provide no Electric Field outer side of the Cable.
- Filler (Optional)** : Non Hygroscopic filler
- Inner Sheath** : The Inner-sheath Comprises a layer of Extruded as per Requirement PVC or LSZH, Applied Under the Armour, Inner-sheath Compound Complying with IEC 60502-2
- Armour** : The Armour Consists of Round Aluminium Wire for Single Core Cable, And Round Galvanized Steel Wire Armour. Applied over the Inner-sheath. Armour Material Complying with IEC 60502-2
- Outer Sheath** : The Outer-sheath Comprises a layer of Extruded as per Requirement PVC or LSZH, Applied Over the Armour to Insulate the Metallic Screen From the Surrounding Medium, to Protect the Metallic Screen From Corrosion, to Reduce the contribution of cables to Fire Propagation and Contribute to Mechanical Protection. Outer sheath Compound Complying with IEC 60502-2
- Temperature Range** : Minimum Conductor Operating Temperature :  $-15^{\circ}\text{C}$  (XLPE INSULATION)  
Maximum Conductor Operating Temperature:  $90^{\circ}\text{C}$  (XLPE INSULATION)  
Short Circuit Temperature:  $250^{\circ}\text{C}$  (5 Seconds Maximum Duration)(XLPE INSULATION)
- Bending Radius** : Single Core Armoured: 20D  
Three Core Armoured: 12D  
D = Outer Diameter of Cable

Note:

As per customer requirement cables can be manufacture as per BS 6622 (PVC sheathed) & BS 7835 (LSZH sheathed).



**3 Core Cables - 3.6/6 KV, CU Or AL Conductor, XLPE Insulation, Metallic Screen: Copper Tape, Steel Wire Armoured, PVC Sheathed**

**DIMENSIONAL DATA**

Catalogue Number	Nominal Cross Section Area	Nominal Insulation Thickness	Inner Sheath Thickness	Armour Wire Size	Nominal Overall Sheath Thickness	Approx Overall Dia
	SQ.MM	MM	MM	MM	MM	MM
NMV6CT*2XWY3C0250	25	2.5	1.2	2.0	2.3	43
NMV6CT*2XWY3C0350	35	2.5	1.3	2.0	2.3	45
NMV6CT*2XWY3C0500	50	2.5	1.3	2.5	2.5	49
NMV6CT*2XWY3C0700	70	2.5	1.4	2.5	2.6	52
NMV6CT*2XWY3C0950	95	2.5	1.5	2.5	2.7	56
NMV6CT*2XWY3C1200	120	2.5	1.5	2.5	2.8	60
NMV6CT*2XWY3C1500	150	2.5	1.6	2.5	2.9	62
NMV6CT*2XWY3C1850	185	2.5	1.6	2.5	3.1	66
NMV6CT*2XWY3C2400	240	2.6	1.7	2.5	3.3	74
NMV6CT*2XWY3C3000	300	2.8	1.8	3.15	3.5	81
NMV6CT*2XWY3C4000	400	3.0	2.0	3.15	3.8	90

**Notes:** \*V(\*) ADD "A" for Aluminium cable & "C" for Copper cable

The above data is indicative & may be changed without prior information.

**ELECTRICAL DATA**

Nominal Cross Section Area	D.C Resistance		Short Circuit Rating of Conductor 1 sec.		Capacitance	Charging Current	Short Circuit Rating of Copper Tape Screen 1 Sec.	Reactance	Inductance
	CU	AL	CU	AL					
Sq.mm	Ω/Km	Ω/Km	kA	kA	pF/m	mA/m	kA	μΩ/m	μΩ/m
25	0.727	1.2	3.6	2.36	272	0.33	0.4	116	370
35	0.524	0.868	5.0	3.3	301	0.36	0.5	108	350
50	0.387	0.641	7.15	4.72	332	0.4	0.5	102	330
70	0.268	0.443	10.01	6.61	383	0.46	0.6	97	310
95	0.193	0.32	13.58	8.97	432	0.52	0.6	92	290
120	0.153	0.253	17.16	11.33	474	0.57	0.7	89	280
150	0.124	0.206	21.45	14.16	511	0.61	0.7	87	280
185	0.0991	0.164	26.45	17.46	562	0.67	0.8	86	270
240	0.0754	0.125	34.32	22.66	602	0.72	0.9	83	260
300	0.0601	0.100	42.9	28.32	622	0.75	1.0	82	260
400	0.0470	0.0778	57.2	37.76	648	0.78	1.1	80	250