



1. COMPACTED COPPER CONDUCTOR
2. CONDUCTOR SEMI-CON
3. XLPE INSULATION
4. INSULATION SEMI-CON
5. COPPER TAPE SCREEN
6. FR PVC BEDDING
7. STEEL WIRE ARMOUR
8. FR PVC OUTER SHEATH

**NEELKANTH CABLES LIMITED**

**DATA SHEET**

**THREE CORE XLPE ARMoured REDUCED FLAME PROPAGATION (FR) MEDIUM VOLTAGE CABLE**

Three Core Cable Description : Copper Conductor, Semi-conducting conductor Screen, XLPE Insulated, Semi-conducting Insulation screen, Metallic screen over Individual Core, FR- PVC Inner Sheathed, Galvanised Steel Wire Armoured, Overall FR-PVC Outer Sheathed, Medium Voltage Cable.

Make	NEELKANTH CABLES LIMITED
Reference Standard	As per SANS:1339:2017
Voltage Rating ( U <sub>o</sub> / U)	3.8/6.6 kV
Maximum Operating Voltage ( U <sub>m</sub> )	7.2 kV
Operating Temperature	90°C
Max. Temp. During Short Circuit	250°C

**Range of Product** Three Core 16 Sq.mm up to 300 Sq.mm

**Application**

These Medium Voltage Three Core Cables are Designed for Electricity Power Distribution ,Suitable for Installation in Power Supply Stations, Commercial ,Industrial and Urban Residential Networks, Indoors and in Cable Ducts, Outdoors, Undergrounds and as well as for Installation on Cable Trays for industries, Switchboards and the power Stations.

**Construction**

<b>Conductor</b>	Annealed Plain Copper Compacted Round Stranded Conductors to carry Current and withstand Pulling Stresses During Cable Laying. Conductors Complying with SANS 1411-1 Class-2
<b>Inner Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over Conductor to Smooth the Electric Field at the Conductor and Firmly Bonded to the Insulation to exclude all air voids ,and Prevent Concentration of electric field of the interface between the Insulation and the Inner Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Insulation</b>	The Insulation of XLPE ( Cross-Linked Polyethylene )Rated Voltage, Lightning Overoltage, Switching Overoltage, and Withstand the Various Voltage Field Stress During the Cable Service Life.as per SANS 1411-4
<b>Core Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over the Insulation . The Screen is Tightly Fitted to the Insulation to Exclude all air Voids, Prevent Concentration of electric field of the interface between the Insulation and the Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Metallic Screen</b>	The Metallic Screen Shall Consist of either Copper Tapes or a Concentric layer of Copper Wires .The Metallic Layer may be applied over the Individual Cores .Metallic Screen Provide no Electric Field outer side the Cable, An Active Conductor for the Capacitive and Zero-Sequence short-circuit current, and Contribution to Mechanical Protection. as per SANS 1339
<b>Filler (Optional)</b>	PVC or Polypropylene yarn
<b>Inner Sheath/Bedding</b>	The Inner-sheath Comprises a layer of Extruded as per Requirement PVC Applied Under the Armour, Inner-sheath Compound Complying with SANS 1411-2
<b>Armour</b>	The Armour Consists of Round Galvanised Steel Wire for Three Core Cable, Applied over the Inner-sheath. Armour Material Complying with SANS 1411-6
<b>Outer Sheath</b>	The Over all Outer-sheath Comprises a layer of Extruded as per Requirement PVC-FR and Applied Over the Armour to Insulate the Mettalic Screen From the Surrounding Medium, to Protect the Mettalic Screen From Corrosion, to Reduce the contribution of cables to Fire Propagation, and Contribute to Mechanical Protection. Outer sheath Compound Complying with SANS 1411-2. Colour: Black with Red Stripe or as per Requirement

**Technical Characteristic**

Voltage Grade	3.8/6.6 kV
Test Voltage	13 kV for 5 Minute ( 3.5 U <sub>o</sub> r.m.s)
Temperature Rating	-15°C to +90°C
Partial Discharge	SANS 6291
Resistivity of Semi-conducting Screen	SANS 6284-2
Flame Retardent	SANS 60332 Part-3-24
Minimum Installation Bending Radius	12(D+d) D= Nominal Diameter of the Cable, d=Nominal Diameter of the Conductor

**Marking & Packing**

Marking over the sheath	NEELKANTH CABLES , CABLE SIZE, 3.8/6.6 kV CU/XLPE/CTS/PVC-FR/SWA/PVC-FR ELECTRIC CABLE , YEAR OF MANUFACTURING
Sequentail Length Marking	Shall be provided on outer sheath at every one Meter
Cable Length	Multiple of 250/500 or as per Requirement
Type of Drum	Wooden Drum Fully Packed with Lagging

Data Sheet No.	10079	Page 1 of 1
Version	01	Issue Date: 29/04/2021



1. COMPACTED COPPER CONDUCTOR
2. CONDUCTOR SEMI-CON
3. XLPE INSULATION
4. INSULATION SEMI-CON
5. COPPER TAPE SCREEN
6. LHFR PVC BEDDING
7. STEEL WIRE ARMOUR
8. LHFR OUTER SHEATH

**NEELKANTH CABLES LIMITED**

**DATA SHEET**

**THREE CORE XLPE ARMURED, REDUCED HALOGEN EMISSION, REDUCED FLAME PROPAGATION (LHFR) MEDIUM VOLTAGE CABLE**

Three Core Cable Description : Copper Conductor, Semi-conducting conductor Screen, XLPE Insulated, Semi-conducting Insulation screen, Metallic screen over Individual Core, LHFR- PVC Inner Sheathed, Galvanised Steel Wire Armoured, Overall LHFR-PVC Outer Sheathed, Medium Voltage Cable.

Make	NEELKANTH CABLES LIMITED
Reference Standard	As per SANS:1339:2017
Voltage Rating ( U <sub>o</sub> / U)	3.8/6.6 kV
Maximum Operating Voltage ( U <sub>m</sub> )	7.2 kV
Operating Temperature	90°C
Max. Temp. During Short Circuit	250°C

**Range of Product** ThreeCore 16 Sq.mm up to 300 Sq.mm

**Application**

These Medium Voltage Three Core Cables are Designed for Electricity Power Distribution ,Suitable for Installation in Power Supply Stations, Commercial ,Industrial and Urban Residential Networks, Indoors and in Cable Ducts, Outdoors, Undergrounds and as well as for Installation on Cable Trays for industries, Switchboards and the power Stations.

**Construction**

<b>Conductor</b>	Annealed Plain Copper Compacted Round Stranded Conductors to carry Current and withstand Pulling Stresses During Cable Laying. Conductors Complying with SANS 1411-1 Class-2
<b>Inner Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over Conductor to Smooth the Electric Field at the Conductor and Firmly Bonded to the Insulation to exclude all air voids ,and Prevent Concentration of electric field of the interface between the Insulation and the Inner Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Insulation</b>	The Insulation of XLPE ( Cross-Linked Polyethylene )Rated Voltage, Lightning Overvoltage, Switching Overvoltage, and Withstand the Various Voltage Field Stress During the Cable Service Life.as per SANS 1411-4
<b>Core Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over the Insulation . The Screen is Tightly Fitted to the Insulation to Exclude all air Voids, Prevent Concentration of electric field of the interface between the Insulation and the Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Metallic Screen</b>	The Metallic Screen Shall Consist of either Copper Tapes or a Concentric layer of Copper Wires .The Metallic Layer may be applied over the Individual Cores .Metallic Screen Provide no Electric Field outer side the Cable, An Active Conductor for the Capacitive and Zero-Sequence short-circuit current, and Contribution to Mechanical Protection. as per SANS 1339
<b>Filler (Optional)</b>	PVC or Polypropylene yarn
<b>Inner Sheath/Bedding</b>	The Inner-sheath Comprises a layer of Extruded as per Requirement PVC-LHFR Applied Under the Armour, Inner-sheath Compound Complying with SANS 1411-2
<b>Armour</b>	The Armour Consists of Round Galvanised Steel Wire for Three Core Cable, Applied over the Inner-sheath. Armour Material Complying with SANS 1411-6
<b>Outer Sheath</b>	The Over all Outer-sheath Comprises a layer of Extruded as per Requirement PVC-LHFR and Applied Over the Armour to Insulate the Metallic Screen From the Surrounding Medium, to Protect the Metallic Screen From Corrosion, to Reduce the contribution of cables to Fire Propagation, and Contribute to Mechanical Protection. Outer sheath Compound Complying with SANS 1411-2. Colour: Black with Blue Stripe or as per Requirement

**Technical Characteristic**

Voltage Grade	3.8/6.6 kV
Test Voltage	13 kV for 5 Minute ( 3.5 U <sub>o</sub> r.m.s)
Temperature Rating	-15°C to +90°C
Partial Discharge	SANS 6291
Resistivity of Semi-conducting Screen	SANS 6284-2
Reduced Flame Retardant	SANS 60332 Part-3-24
Reduced Halogen Emission	SANS 5956
Minimum Installation Bending Radius	12(D+d) D= Nominal Diameter of the Cable, d=Nominal Diameter of the Conductor

**Marking & Packing**

Marking over the sheath	NEELKANTH CABLES , CABLE SIZE, 3.8/6.6 kV CU/XLPE/CTS/PVC-LHFR/SWA/PVC-LHFR ELECTRIC CABLE , YEAR OF MANUFACTURING
Sequential Length Marking	Shall be provided on outer sheath at every one Meter
Cable Length	Multiple of 250/500 or as per Requirement
Type of Drum	Wooden Drum Fully Packed with Lagging

Data Sheet No.	10080	Page 1 of 1
Version	01	Issue Date: 29/04/2021



1. COMPACTED COPPER CONDUCTOR
2. CONDUCTOR SEMI-CON
3. XLPE INSULATION
4. INSULATION SEMI-CON
5. COPPER TAPE SCREEN
6. NHLFSR BEDDING
7. STEEL WIRE ARMOUR
8. NHLFSR OUTER SHEATH

### NEELKANTH CABLES LIMITED

#### DATA SHEET

#### THREE CORE XLPE ARMoured, ZERO HALOGEN EMISSION, REDUCED SMOKE EMISSION, REDUCED FLAME PROPAGATION (NHLFSR) MEDIUM VOLTAGE CABLE

Three Core Cable Description : Copper Conductor, Semi-conducting conductor Screen, XLPE Insulated, Semi-conducting Insulation screen, Metallic screen over Individual Core, NHLFSR (Polyolefin) Inner Sheathed, Galvanised Steel Wire Armoured, Overall NHLFSR (Polyolefin) Outer Sheathed, Medium Voltage Cable.

Make	NEELKANTH CABLES LIMITED
Reference Standard	As per SANS:1339:2017
Voltage Rating ( Uo / U)	3.8/6.6 kV
Maximum Operating Voltage ( Um)	7.2 kV
Operating Temperature	90°C
Max. Temp. During Short Circuit	250°C

**Range of Product** Three Core 16 Sq.mm up to 300 Sq.mm

#### Application

These Medium Voltage Three Core Cables are Designed for Electricity Power Distribution ,Suitable for Installation in Power Supply Stations, Commercial ,Industrial and Urban Residential Networks, Indoors and in Cable Ducts, Outdoors, Undergrounds and as well as for Installation on Cable Trays for industries, Switchboards and the power Stations.

#### Construction

<b>Conductor</b>	Annealed Plain Copper Compacted Round Stranded Conductors to carry Current and withstand Pulling Stresses During Cable Laying. Conductors Complying with SANS 1411-1 Class-2
<b>Inner Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over Conductor to Smooth the Electric Field at the Conductor and Firmly Bonded to the Insulation to exclude all air voids ,and Prevent Concentration of electric field of the interface between the Insulation and the Inner Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Insulation</b>	The Insulation of XLPE ( Cross-Linked Polyethylene )Rated Voltage, Lightning Overvoltage, Switching Overvoltage, and Withstand the Various Voltage Field Stress During the Cable Service Life.as per SANS 1411-4
<b>Core Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over the Insulation . The Screen is Tightly Fitted to the Insulation to Exclude all air Voids, Prevent Concentration of electric field of the interface between the Insulation and the Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Metallic Screen</b>	The Metallic Screen Shall Consist of either Copper Tapes or a Concentric layer of Copper Wires .The Metallic Layer may be applied over the Individual Cores .Metallic Screen Provide no Electric Field outer side the Cable, An Active Conductor for the Capacitive and Zero-Sequence short-circuit current, and Contribution to Mechanical Protection. as per SANS 1339
<b>Filler (Optional)</b>	PVC or Polypropylene yarn
<b>Inner Sheath/Bedding</b>	The Inner-sheath Comprises a layer of Extruded as per Requirement NHLFSR (Polyolefin) Applied Under the Armour, Inner-sheath Compound Complying with SANS 1411-5
<b>Armour</b>	The Armour Consists of Round Galvanised Steel Wire for Three Core Cable, Applied over the Inner-sheath. Armour Material Complying with SANS 1411-6
<b>Outer Sheath</b>	The Over all Outer-sheath Comprises a layer of Extruded as per Requirement NHLFSR (Polyolefin) and Applied Over the Armour to Insulate the Metallic Screen From the Surrounding Medium, to Protect the Metallic Screen From Corrosion, to Reduce the contribution of cables to Fire Propagation, and Contribute to Mechanical Protection. Outer sheath Compound Complying with SANS 1411-5. Colour: Black with White Stripe or as per Requirement

#### Technical Characteristic

Voltage Grade	3.8/6.6 kV
Test Voltage	13 kV for 5 Minute ( 3.5 Uo r.m.s)
Temperature Rating	-15°C to +90°C
Partial Discharge	SANS 6291
Resistivity of Semi-conducting Screen	SANS 6284-2
Reduced Flame Retardent	SANS 60332 Part-3-24
Zero Halogen Emission	SANS 60754-2
Minimum Installation Bending Radius	12(D+d) D= Nominal Diameter of the Cable, d=Nominal Diameter of the Conductor

#### Marking & Packing

Marking over the sheath	NEELKANTH CABLES , CABLE SIZE, 3.8/6.6 kV CU/XLPE/CTS/NHLFSR/SWA/NHLFSR ELECTRIC CABLE , YEAR
Sequentail Length Marking	Shall be provided on outer sheath at every one Meter
Cable Length	Multiple of 250/500 or as per Requirement
Type of Drum	Wooden Drum Fully Packed with Lagging

Data Sheet No.	10081	Page 1 of 1
Version	01	Issue Date: 29/04/2021



1. COMPACTED COPPER CONDUCTOR
2. CONDUCTOR SEMI-CON
3. XLPE INSULATION
4. INSULATION SEMI-CON
5. COPPER TAPE SCREEN
6. FR PVC BEDDING
7. STEEL WIRE ARMOUR
8. PE OUTER SHEATH

**NEELKANTH CABLES LIMITED  
DATA SHEET**

**THREE CORE XLPE ARMoured, UV STABILIZED POLYETHYLENE OUTER SHEATHED (PE) MEDIUM VOLTAGE CABLE**

Three Core Cable Description : Copper Conductor,Semi-conducting conductor Screen,XLPE Insulated,Semi-conducting Insulation screen, Metallic screen over Individual Core, PVC-FR Inner Sheathed, Galvanised Steel Wire Armoured, Overall UV Stabilized Polyethylene (PE) Outer Sheathed,Medium Voltage Cable.

Make	NEELKANTH CABLES LIMITED
Reference Standard	As per SANS:1339:2017
Voltage Rating ( Uo / U)	3.8/6.6 kV
Maximum Operating Voltage ( Um)	7.2 kV
Operating Temperature	90°C
Max. Temp. During Short Circuit	250°C

**Range of Product** Three Core 16 Sq.mm up to 300 Sq.mm

**Application**

These Medium Voltage Three Cores Cables are Designed for Electricity Power Distribution ,Suitable for Installation in Power Supply Stations,Commercial ,Industrial and Urban Residential Networks,Indoors and in Cable Ducts,Outdoors,Undergrounds and as well as for Installation on Cable Trays for industries, Switchboards and the power Stations.

**Construction**

<b>Conductor</b>	Annealed Plain Copper Compacted Round Stranded Conductors to carry Current and withstand Pulling Stresses During Cable Laying. Conductors Complying with SANS 1411-1 Class-2
<b>Inner Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over Conductor to Smooth the Electric Field at the Conductor and Firmly Bonded to the Insulation to exclude all air voids ,and Prevent Concentration of electric field of the interface between the Insulation and the Inner Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Insulation</b>	The Insulation of XLPE ( Cross-Linked Polyethylene )Rated Voltage, Lightning Overvoltage,Switching Overvoltage, and Withstand the Various Voltage Field Stress During the Cable Service Life.as per SANS 1411-4
<b>Core Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over the Insulation . The Screen is Tightly Fitted to the Insulation to Exclude all air Voids,Prevent Concentration of electric field of the interface between the Insulation and the Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Metallic Screen</b>	The Metallic Screen Shall Consist of either Copper Tapes or a Concentric layer of Copper Wires .The Metallic Layer may be applied over the Individual Cores .Metallic Screen Provide no Electric Field outer side the Cable,An Active Conductor for the Capacitive and Zero-Sequence short-circuit current,and Contribution to Mechanical Protection. as per SANS 1339
<b>Filler (Optional)</b>	PVC or Polypropylene yarn
<b>Inner Sheath/Bedding</b>	The Inner-sheath Comprises a layer of Extruded as per Requirement PVC-FR, Applied Under the Armour,Inner-sheath Compound Complying with SANS 1411-2
<b>Armour</b>	The Armour Consists of Round Galvanised Steel Wire for Three Core Cable, Applied over the Inner-sheath.Armour Material Complying with SANS 1411-6
<b>Outer Sheath</b>	The Over all Outer-sheath Comprises a layer of Extruded as per Requirement Polyethylene (PE) and Applied Over the Armour to Insulate the Metallc Screen From the Surrounding Medium,to Protect the Metallc Screen From Corrosion,to Reduce the contribution of cables to Fire Propagation,and Contribute to Mechanical Protection. Outer sheath Compound Complying with SANS 1411-7.  Colour: Black or as per Requirement

**Technical Characteristic**

Voltage Grade	3.8/6.6 kV
Test Voltage	13 kV for 5 Minute ( 3.5 Uo r.m.s)
Temperature Rating	-15°C to +90°C
Partial Discharge	SANS 6291
Resistivity of Semi-conducting Screen	SANS 6284-2
Minimum Installation Bending Radius	12(D+d) D= Nominal Diameter of the Cable, d=Nominal Diameter of the Conductor

**Marking & Packing**

Marking over the sheath	NEELKANTH CABLES , CABLE SIZE, 3.8/6.6 kV CU/XLPE/CTS/PVC-FR/SWA/PE, ELECTRIC CABLE , YEAR OF MANUFACTURING
Sequentail Length Marking	Shall be provided on outer sheath at every one Meter
Cable Length	Multiple of 250/500 or as per Requirement
Type of Drum	Wooden Drum Fully Packed with Lagging

Data Sheet No.	10082	Page 1 of 1
Version	01	Issue Date: 29/04/2021



1. COMPACTED COPPER CONDUCTOR
2. CONDUCTOR SEMI-CON
3. XLPE INSULATION
4. INSULATION SEMI-CON
5. COPPER TAPE SCREEN
6. FR PVC BEDDING
7. FR PVC OUTER SHEATH

## NEELKANTH CABLES LIMITED

### DATA SHEET

#### THREE CORE XLPE UNARMOURED REDUCED FLAME PROPAGATION (FR) MEDIUM VOLTAGE CABLE

Three Core Cable Description : Copper Conductor,Semi-conducting conductor Screen,XLPE Insulated,Semi-conducting Insulation screen, Metallic screen over Individual Core,FR- PVC Inner Sheathed, Overall FR-PVC Outer Sheathed,Medium Voltage Unarmoured Cable.

Make	NEELKANTH CABLES LIMITED
Reference Standard	As per SANS:1339:2017
Voltage Rating ( U <sub>o</sub> / U)	3.8/6.6 kV
Maximum Operating Voltage ( U <sub>m</sub> )	7.2 kV
Operating Temperature	90°C
Max. Temp. During Short Circuit	250°C

**Range of Product** Three Core 16 Sq.mm up to 300 Sq.mm

#### Application

These Medium Voltage Three Core Cables are Designed for Electricity Power Distribution ,Suitable for Installation in Power Supply Stations,Commercial ,Industrial and Urban Residential Networks,Indoors and in Cable Ducts,Outdoors,Undergrounds and as well as for Installation on Cable Trays for industries, Switchboards and the power Stations.

#### Construction

<b>Conductor</b>	Annealed Plain Copper Compacted Round Stranded Conductors to carry Current and withstand Pulling Stresses During Cable Laying. Conductors Complying with SANS 1411-1 Class-2
<b>Inner Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over Conductor to Smooth the Electric Field at the Conductor and Firmly Bonded to the Insulation to exclude all air voids ,and Prevent Concentration of electric field of the interface between the Insulation and the Inner Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Insulation</b>	The Insulation of XLPE ( Cross-Linked Polyethylene )Rated Voltage, Lightning Overoltage,Switching Overvoltage, and Withstand the Various Voltage Field Stress During the Cable Service Life.as per SANS 1411-4
<b>Core Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over the Insulation . The Screen is Tightly Fitted to the Insulation to Exclude all air Voids,Prevent Concentration of electric field of the interface between the Insulation and the Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Metallic Screen</b>	The Metallic Screen Shall Consist of either Copper Tapes or a Concentric layer of Copper Wires .The Metallic Layer may be applied over the Individual Cores .Metallic Screen Provide no Electric Field outer side the Cable,An Active Conductor for the Capactive and Zero-Sequence short-circuit current,and Contribution to Mechanical Protection. as per SANS 1339
<b>Filler (Optional)</b>	PVC or Polypropylene yarn
<b>Inner Sheath/Bedding</b>	The Inner-sheath Comprises a layer of Extruded as per Requirement PVC Applied Under the Armour,Inner-sheath Compound Complying with SANS 1411-2
<b>Outer Sheath</b>	The Over all Outer-sheath Comprises a layer of Extruded as per Requirement PVC-FR and Applied Over the Armour to Insulate the Mettalic Screen From the Surrounding Medium,to Protact the Mettalic Screen From Corrosion,to Reduce the contribution of cables to Fire Propagation,and Contribute to Mechanical Protection. Outer sheath Compound Complying with SANS 1411-2. Colour: Black with Red Stripe or as per Requirement

#### Technical Characteristic

Voltage Grade	3.8/6.6 kV
Test Voltage	13 kV for 5 Minute ( 3.5 U <sub>o</sub> r.m.s)
Temperature Rating	-15°C to +90°C
Partial Discharge	SANS 6291
Resistivity of Semi-conducting Screen	SANS 6284-2
Flame Retardent	SANS 60332 Part-3-24
Minimum Installation Bending Radius	15(D+d) D= Nominal Diameter of the Cable, d=Nominal Diameter of the Conductor

#### Marking & Packing

Marking over the sheath	NEELKANTH CABLES , CABLE SIZE, 3.8/6.6 kV CU/XLPE/CTS/PVC-FR/PVC-FR ELECTRIC CABLE , YEAR OF MANUFACTURING
Sequentail Length Marking	Shall be provided on outer sheath at every one Meter
Cable Length	Multiple of 250/500 or as per Requirement
Type of Drum	Wooden Drum Fully Packed with Lagging

Data Sheet No.	10083	Page 1 of 1
Version	01	Issue Date: 29/04/2021



1. COMPACTED COPPER CONDUCTOR
2. CONDUCTOR SEMI-CON
3. XLPE INSULATION
4. INSULATION SEMI-CON
5. COPPER TAPE SCREEN
6. LHFR BEDDING
7. LHFR OUTER SHEATH

**NEELKANTH CABLES LIMITED  
DATA SHEET**

**THREE CORE XLPE UNARMoured, REDUCED HALOGEN EMISSION, REDUCED FLAME PROPAGATION (LHFR) MEDIUM VOLTAGE CABLE**

Three Core Cable Description : Copper Conductor,Semi-conducting conductor Screen,XLPE Insulated,Semi-conducting Insulation screen, Metallic screen over Individual Core,LHFR- PVC Inner Sheathed, Overall LHFR-PVC Outer Sheathed,Medium Voltage Unarmoured Cable.

Make	NEELKANTH CABLES LIMITED
Reference Standard	As per SANS:1339:2017
Voltage Rating ( U <sub>o</sub> / U)	3.8/6.6 kV
Maximum Operating Voltage ( U <sub>m</sub> )	7.2 kV
Operating Temperature	90°C
Max. Temp. During Short Circuit	250°C

**Range of Product** ThreeCore 16 Sq.mm up to 300 Sq.mm

**Application**

These Medium Voltage Three Core Cables are Designed for Electricity Power Distribution ,Suitable for Installation in Power Supply Stations,Commercial ,Industrial and Urban Residential Networks,Indoors and in Cable Ducts,Outdoors,Undergrounds and as well as for Installation on Cable Trays for industries, Switchboards and the power Stations.

**Construction**

<b>Conductor</b>	Annealed Plain Copper Compacted Round Stranded Conductors to carry Current and withstand Pulling Stresses During Cable Laying. Conductors Complying with SANS 1411-1 Class-2
<b>Inner Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over Conductor to Smooth the Electric Field at the Conductor and Firmly Bonded to the Insulation to exclude all air voids ,and Prevent Concentration of electric field of the interface between the Insulation and the Inner Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Insulation</b>	The Insulation of XLPE ( Cross-Linked Polyethylene )Rated Voltage, Lightning Overoltage,Switching Overvoltage, and Withstand the Various Voltage Field Stress During the Cable Service Life.as per SANS 1411-4
<b>Core Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over the Insulation . The Screen is Tightly Fitted to the Insulation to Exclude all air Voids,Prevent Concentration of electric field of the interface between the Insulation and the Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Metallic Screen</b>	The Metallic Screen Shall Consist of either Copper Tapes or a Concentric layer of Copper Wires .The Metallic Layer may be applied over the Individual Cores .Metallic Screen Provide no Electric Field outer side the Cable,An Active Conductor for the Capacitive and Zero-Sequence short-circuit current,and Contribution to Mechanical Protection. as per SANS 1339
<b>Filler (Optional)</b>	PVC or Polypropylene yarn
<b>Inner Sheath/Bedding</b>	The Inner-sheath Comprises a layer of Extruded as per Requirement PVC-LHFR Applied Under the Armour,Inner-sheath Compound Complying with SANS 1411-2
<b>Outer Sheath</b>	The Over all Outer-sheath Comprises a layer of Extruded as per Requirement PVC-LHFR and Applied Over the Armour to Insulate the Mettalic Screen From the Surrounding Medium,to Protect the Mettalic Screen From Corrosion,to Reduce the contribution of cables to Fire Propagation,and Contribute to Mechanical Protection. Outer sheath Compound Complying with SANS 1411-2. Colour: Black with Blue Stripe or as per Requirement

**Technical Characteristic**

Voltage Grade	3.8/6.6 kV
Test Voltage	13 kV for 5 Minute ( 3.5 U <sub>o</sub> r.m.s)
Temperature Rating	-15°C to +90°C
Partial Discharge	SANS 6291
Resistivity of Semi-conducting Screen	SANS 6284-2
Reduced Flame Retardent	SANS 60332 Part-3-24
Reduced Halogen Emission	SANS 5956
Minimum Installation Bending Radius	15(D+d) D= Nominal Diameter of the Cable, d=Nominal Diameter of the Conductor

**Marking & Packing**

Marking over the sheath	NEELKANTH CABLES , CABLE SIZE, 3.8/6.6 kV CU/XLPE/CTS/PVC-LHFR/PVC-LHFR ELECTRIC CABLE , YEAR OF MANUFACTURING
Sequentail Length Marking	Shall be provided on outer sheath at every one Meter
Cable Length	Multiple of 250/500 or as per Requirement
Type of Drum	Wooden Drum Fully Packed with Lagging

Data Sheet No.	10084	Page 1 of 1
Version	01	Issue Date: 29/04/2021





1. COMPACTED COPPER CONDUCTOR
2. CONDUCTOR SEMI-CON
3. XLPE INSULATION
4. INSULATION SEMI-CON
5. COPPER TAPE SCREEN
6. NHLFSR BEDDING
7. NHLFSR OUTER SHEATH

**NEELKANTH CABLES LIMITED  
DATA SHEET**

**THREE CORE XLPE UNARMOURED, ZERO HALOGEN EMISSION, REDUCED SMOKE EMISSION, REDUCED FLAME PROPAGATION (NHLFSR) MEDIUM VOLTAGE CABLE**

Three Core Cable Description : Copper Conductor, Semi-conducting conductor Screen, XLPE Insulated, Semi-conducting Insulation screen, Metallic screen over Individual Core, NHLFSR Inner Sheath, Overall NHLFSR (Polyolefin) Outer Sheathed, Medium Voltage Unarmoured Cable.

Make	NEELKANTH CABLES LIMITED
Reference Standard	As per SANS:1339:2017
Voltage Rating ( U <sub>o</sub> / U )	3.8/6.6 kV
Maximum Operating Voltage ( Um )	7.2 kV
Operating Temperature	90°C
Max. Temp. During Short Circuit	250°C

**Range of Product** Three Core 16 Sq.mm up to 300 Sq.mm

**Application**

These Medium Voltage Three Core Cables are Designed for Electricity Power Distribution , Suitable for Installation in Power Supply Stations, Commercial ,Industrial and Urban Residential Networks, Indoors and in Cable Ducts, Outdoors, Undergrounds and as well as for Installation on Cable Trays for industries, Switchboards and the power Stations.

**Construction**

<b>Conductor</b>	Annealed Plain Copper Compacted Round Stranded Conductors to carry Current and withstand Pulling Stresses During Cable Laying. Conductors Complying with SANS 1411-1 Class-2
<b>Inner Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over Conductor to Smooth the Electric Field at the Conductor and Firmly Bonded to the Insulation to exclude all air voids ,and Prevent Concentration of electric field of the interface between the Insulation and the Inner Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Insulation</b>	The Insulation of XLPE ( Cross-Linked Polyethylene ) Rated Voltage, Lightning Overvoltage, Switching Overvoltage, and Withstand the Various Voltage Field Stress During the Cable Service Life. as per SANS 1411-4
<b>Core Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over the Insulation . The Screen is Tightly Fitted to the Insulation to Exclude all air Voids, Prevent Concentration of electric field of the interface between the Insulation and the Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Metallic Screen</b>	The Metallic Screen Shall Consist of either Copper Tapes or a Concentric layer of Copper Wires .The Metallic Layer may be applied over the Individual Cores .Metallic Screen Provide no Electric Field outer side the Cable, An Active Conductor for the Capacitive and Zero-Sequence short-circuit current, and Contribution to Mechanical Protection. as per SANS 1339
<b>Filler (Optional)</b>	PVC or Polypropylene yarn
<b>Inner Sheath/Bedding</b>	The Inner-sheath Comprises a layer of Extruded as per Requirement NHLFSR (Polyolefin) Applied Under the Armour, Inner-sheath Compound Complying with SANS 1411-5
<b>Outer Sheath</b>	The Over all Outer-sheath Comprises a layer of Extruded as per Requirement NHLFSR (Polyolefin) and Applied Over the Armour to Insulate the Metallic Screen From the Surrounding Medium, to Protect the Metallic Screen From Corrosion, to Reduce the contribution of cables to Fire Propagation, and Contribute to Mechanical Protection. Outer sheath Compound Complying with SANS 1411-5. Colour: Black with White Stripe or as per Requirement

**Technical Characteristic**

Voltage Grade	3.8/6.6 kV
Test Voltage	13 kV for 5 Minute ( 3.5 U <sub>o</sub> r.m.s )
Temperature Rating	-15°C to +90°C
Partial Discharge	SANS 6291
Resistivity of Semi-conducting Screen	SANS 6284-2
Reduced Flame Retardent	SANS 60332 Part-3-24
Zero Halogen Emission	SANS 60754-2
Minimum Installation Bending Radius	15(D+d) D= Nominal Diameter of the Cable, d=Nominal Diameter of the Conductor

**Marking & Packing**

Marking over the sheath	NEELKANTH CABLES , CABLE SIZE, 3.8/6.6 kV CU/XLPE/CTS/NHLFSR/NHLFSR ELECTRIC CABLE , YEAR OF MANUFACTURING
Sequential Length Marking	Shall be provided on outer sheath at every one Meter
Cable Length	Multiple of 250/500 or as per Requirement
Type of Drum	Wooden Drum Fully Packed with Lagging

Data Sheet No.	10085	Page 1 of 1
Version	01	Issue Date: 29/04/2021



1. COMPACTED COPPER CONDUCTOR
2. CONDUCTOR SEMI-CON
3. XLPE INSULATION
4. INSULATION SEMI-CON
5. COPPER TAPE SCREEN
6. FR PVC BEDDING
7. PE OUTER SHEATH

**NEELKANTH CABLES LIMITED  
DATA SHEET**

**THREE CORE XLPE UNARMOURED, UV STABILIZED POLYETHYLENE OUTER SHEATHED (PE) MEDIUM VOLTAGE CABLE**

Three Core Cable Description : Copper Conductor,Semi-conducting conductor Screen,XLPE Insulated,Semi-conducting Insulation screen, Metallic screen over Individual Core, PVC-FR Inner Sheathed, Overall UV Stabilized Polyethylene (PE) Outer Sheathed,Medium Voltage Unarmoured Cable.

Make	NEELKANTH CABLES LIMITED
Reference Standard	As per SANS:1339:2017
Voltage Rating ( U <sub>o</sub> / U)	3.8/6.6 kV
Maximum Operating Voltage ( U <sub>m</sub> )	7.2 kV
Operating Temperature	90°C
Max. Temp. During Short Circuit	250°C

**Range of Product** Three Core 16 Sq.mm up to 300 Sq.mm

**Application**

These Medium Voltage Three Core Cores Cables are Designed for Electricity Power Distribution ,Suitable for Installation in Power Supply Stations,Commercial , Industrial and Urban Residential Networks,Indoors and in Cable Ducts,Outdoors,Undergrounds and as well as for Installation on Cable Trays for industries, Switchboards and the power Stations.

**Construction**

<b>Conductor</b>	Annealed Plain Copper Compacted Round Stranded Conductors to carry Current and withstand Pulling Stresses During Cable Laying. Conductors Complying with SANS 1411-1 Class-2
<b>Inner Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over Conductor to Smooth the Electric Field at the Conductor and Firmly Bonded to the Insulation to exclude all air voids ,and Prevent Concentration of electric field of the interface between the Insulation and the Inner Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Insulation</b>	The Insulation of XLPE ( Cross-Linked Polyethylene )Rated Voltage, Lightning Overvoltage,Switching Overvoltage, and Withstand the Various Voltage Field Stress During the Cable Service Life.as per SANS 1411-4
<b>Core Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over the Insulation . The Screen is Tightly Fitted to the Insulation to Exclude all air Voids,Prevent Concentration of electric field of the interface between the Insulation and the Semi-Conductor. Semi-Conducting Compound Complying with SANS 1339
<b>Metallic Screen</b>	The Metallic Screen Shall Consist of either Copper Tapes or a Concentric layer of Copper Wires .The Metallic Layer may be applied over the Individual Cores .Metallic Screen Provide no Electric Field outer side the Cable,An Active Conductor for the Capacitive and Zero-Sequence short-circuit current,and
<b>Filler (Optional)</b>	PVC or Polypropylene yarn
<b>Inner Sheath/Bedding</b>	The Inner-sheath Comprises a layer of Extruded as per Requirement PVC-FR Applied Under the Armour,Inner-sheath Compound Complying with SANS 1411-2
<b>Outer Sheath</b>	The Over all Outer-sheath Comprises a layer of Extruded as per Requirement Polyethylene (PE) and Applied Over the Armour to Insulate the Metallc Screen From the Surrounding Medium,to Protect the Metallc Screen From Corrosion,to Reduce the contribution of cables to Fire Propagation,and Contribute to Mechanical Protection. Outer sheath Compound Complying with SANS 1411-7.  Colour: Black or as per Requirement

**Technical Characteristic**

Voltage Grade	3.8/6.6 kV
Test Voltage	13 kV for 5 Minute ( 3.5 U <sub>o</sub> r.m.s)
Temperature Rating	-15°C to +90°C
Partial Discharge	SANS 6291
Resistivity of Semi-conducting Screen	SANS 6284-2
Minimum Installation Bending Radius	15(D+d) D= Nominal Diameter of the Cable, d=Nominal Diameter of the Conductor

**Marking & Packing**

Marking over the sheath	NEELKANTH CABLES , CABLE SIZE, 3.8/6.6 kV CU/XLPE/CTS/PVC-FR/PE, ELECTRIC CABLE , YEAR OF MANUFACTURING
Sequentail Length Marking	Shall be provided on outer sheath at every one Meter
Cable Length	Multiple of 250/500 or as per Requirement
Type of Drum	Wooden Drum Fully Packed with Lagging

Data Sheet No.	10086	Page 1 of 1
Version	01	Issue Date: 29/04/2021